

# TECHNICAL REPORT

**Rotating electrical machinery – Natural graphite brush for slip-ring in wound rotor-type induction motor – Application information**

IECNORM.COM : Click to view the full PDF of IEC TR 63021:2016



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

#### IEC Catalogue - [webstore.iec.ch/catalogue](http://webstore.iec.ch/catalogue)

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

#### IEC publications search - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

#### IEC Glossary - [std.iec.ch/glossary](http://std.iec.ch/glossary)

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [csc@iec.ch](mailto:csc@iec.ch).

IECNORM.COM : Click to view the details of IEC TC 37, 77, 86 and CISPR

# TECHNICAL REPORT

---

**Rotating electrical machinery – Natural graphite brush for slip-ring in wound rotor-type induction motor – Application information**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 29.160.01

ISBN 978-2-8322-3602-4

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions .....	6
4 General remarks.....	7
5 General conditions of brush and slip-ring for stability in the operation of a wound rotor-type induction motor .....	7
5.1 Fire-spark .....	7
5.2 Life .....	7
5.3 Temperature .....	8
5.4 Dust diffusion.....	8
5.5 Noise.....	8
6 Operating characteristics of natural graphite brush for slip-ring in a wound rotor-type induction motor .....	8
6.1 Current density .....	8
6.2 Vibration absorbing ability .....	8
6.3 Temperature .....	8
6.4 Brush's pressure .....	9
7 Testing method.....	9
8 Application result.....	9
8.1 Fire-spark .....	9
8.2 Wear and life of brush .....	9
8.3 Life of slip-ring .....	9
8.4 Environmental pollution.....	9
8.4.1 Dust diffusion by wear of brush .....	9
8.4.2 Pollution by noise.....	10
8.5 Economic profit.....	10
8.5.1 Brush price .....	10
8.5.2 Brush life .....	10
8.5.3 No accident due to dust diffusion and slip-ring's life .....	10
Annex A (informative) Data from practical application.....	11
Bibliography .....	12
Table 1 – Typical kinds of brushes .....	7
Table 2 – NG-brush's bulk density, electric resistivity and current density compared with the copper brush.....	8
Table 3 – Comparison of properties for the assessment of vibration absorbing ability .....	8
Table 4 – Wear and life of brush .....	9
Table 5 – Comparison of wear of NG-brush and copper brush.....	9
Table A.1 – Data from practical application.....	11

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## ROTATING ELECTRICAL MACHINERY –

**Natural graphite brush for slip-ring in wound  
rotor-type induction motor – Application information**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a Technical Report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 63021, which is a Technical Report, has been prepared by IEC technical committee 2: Rotating machinery.

The text of this Technical Report is based on the following documents:

Enquiry draft	Report on voting
2/1794/DTR	2/1823A/RVC

Full information on the voting for the approval of this Technical Report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IECNORM.COM : Click to view the full PDF of IEC TR 63021:2016

## INTRODUCTION

This Technical Report has been prepared after considering implications of the withdrawal of IEC PAS 62072:2005 and its potential conversion into an International Standard, and after analysing practical information obtained through the application of natural graphite (NG) brush for slip-ring in wound-rotor type induction motor, compared with copper brush.

Practical values obtained through the application of NG-brushes into slip-rings in various kinds of wound rotor-type induction motor are given in Annex A.

IECNORM.COM : Click to view the full PDF of IEC TR 63021:2016

## ROTATING ELECTRICAL MACHINERY –

### Natural graphite brush for slip-ring in wound rotor-type induction motor – Application information

#### 1 Scope

This document presents technical characteristics, application results and practical information on NG-brush for slip-ring obtained through the application of NG-brush in various kinds of wound rotor-type induction motor (large-size water pump, belt conveyer, lift, winder motor, grinding mill and crusher in coal or ore mine; crane, rolling mill, compressor and winder motor for boring in oil or gas facility).

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60413, *Test procedures for determining physical properties of brush materials for electrical machines*

IEC 60773, *Test methods and apparatus for measurement of the operational characteristics of brushes*

#### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

##### 3.1

##### **fire-spark**

glittering phenomenon observed macroscopically between the brush and slip-ring during the operation of a wound rotor-type induction motor

##### 3.2

##### **life**

critical time since the brushes have been installed into the wound rotor-type induction motor and started to operate until the brush and the slip-ring can no longer contribute to the motor's operation

##### 3.3

##### **dust diffusion**

phenomenon whereby fine powders, caused by wear of the brush, diffuse in air during the operation of a wound rotor-type induction motor

**3.4****noise**

acoustic signal of high intensity caused between the brush and slip-ring among the acoustic signals of several wavelengths made during the operation of a wound rotor-type induction motor

**3.5****vibration absorbing ability**

ability of the brush to absorb or decrease electromagnetic and mechanical vibrations caused during the operation of a wound rotor-type induction motor

**4 General remarks**

Generally, it is traditional to use the metal grade brush including copper brush for the wound rotor-type induction motor.

The metal grade brush, including copper brushes, can usually damage the slip-ring by the fire-spark during operation. The dust generated by the wear of the copper brush can be the cause of accidents and also contaminates the environment. Compared with the formerly used copper brush, the NG-brush shows high operating characteristics when it is used for the slip-ring of a wound rotor-type induction motor. There is nearly no fire-spark between the NG-brush and slip-ring and no environmental pollution due to reduced wear. It also has sufficient ability of electromotion.

Table 1 shows the size and quantity of typical NG-brushes that are used for wound rotor-type induction motors of various powers.

**Table 1 – Typical kinds of brushes**

No.	Denomination	Size	Quantity (for a motor)	Power
		mm		kW
1	motor for elevator	25×32×60	36	180
2	motor for compressor	25×32×60	9 to 18	75
3	motor for winder	25×32×60	9 to 18	250
4	motor for boring	25×32×60	6 to 36	1 600 to 3 000
5	motor for grinding mill	25×32×60	18	120 to 250
6	motor for crusher	25×32×60	18	120 to 250

**5 General conditions of brush and slip-ring for stability in the operation of a wound rotor-type induction motor****5.1 Fire-spark**

Fire-spark causes damage to the surface of the slip-ring. In severe conditions, it bursts out and becomes the cause of accidents or explosions.

**5.2 Life**

The life of the brush and the slip-ring are the main conditions for the motor's normal operation. The life of the brush is decided by its wear. The life of the slip-ring is also mutually related to the physical characteristics of the brush.

### 5.3 Temperature

The proper temperature of the brush is a function of the brush current density, the coefficient of friction and the air flow in the area of the brush and slip-ring.

### 5.4 Dust diffusion

The dust caused by the wear of the brush lowers the insulation resistance of the motor winding and contaminates the atmosphere around the motor. Dust diffusion can be characterized by the wear of brush.

### 5.5 Noise

The rotor vibration can be controlled with the vibration absorbing ability of the brush. The vibration absorbing ability is mutually related to the bulk density of brush.

## 6 Operating characteristics of natural graphite brush for slip-ring in a wound rotor-type induction motor

### 6.1 Current density

Natural graphite brush for slip-ring in a wound rotor-type induction motor is three to four times lighter than copper brush.

**Table 2 – NG-brush's bulk density, electric resistivity and current density compared with the copper brush**

Property	NG-brush	Copper brush
Bulk density, g/cm <sup>3</sup>	1,35	4,5 to 5,5
Electric resistivity, $\mu\Omega\text{m}$	5 to 15	0,05 to 3
Current density, A/cm <sup>2</sup>	5 to 25	10 to 25

Table 2 shows that the electric resistivity of the NG-brush is 100 times higher than that of the copper brush, but that the current density is nearly equal.

### 6.2 Vibration absorbing ability

The higher the porosity and the lower the friction coefficient of the brush, the more the vibration caused by the operation of the wound rotor-type induction motor decreases. See Table 3.

**Table 3 – Comparison of properties for the assessment of vibration absorbing ability**

Property	NG-brush	Copper brush
Porosity, %	43	1 to 2
Friction coefficient	0,12	2

Since the coefficient of friction of the NG-brush is 16 times lower than that of the copper brush and its porosity is 43 times higher than that of the copper brush, the NG-brush has the higher vibration absorbing ability.

### 6.3 Temperature

Permissible temperature of NG-brush during its operation is 80 °C.

## 6.4 Brush's pressure

Copper brush's pressure is usually above 20 kPa to 40 kPa. NG-brush, however, has characteristics sufficient to operate in a range of 9 kPa to 10 kPa.

## 7 Testing method

The test method on the physical properties and operating characteristics of NG-brush is performed in accordance with IEC 60413 and IEC 60773.

## 8 Application result

### 8.1 Fire-spark

There's nearly no fire-spark between brush and slip-ring, because of the lighter weight and current density of NG-brush.

### 8.2 Wear and life of brush

**Table 4 – Wear and life of brush**

Brush's weight before testing (g)		Brush's wear after testing (g)		Life (year)		Testing period (h)
copper	NG	copper	NG	copper	NG	
288	64,8	22,5	0,6	0,8	≥ 10	1 000

Based on the consideration of the brush's life (see Table 4 and Annex A) when using the NG-brush in several units, it was evaluated that the life of NG-brush is above 36 months under very unfavourable conditions and about 360 months (when operating for 10 h per day) under normal conditions.

NOTE The unfavourable conditions include relative humidity of more than 80 %, on-off times per hour above 20, vibrating width above 100 µm and ambient temperature above +40 °C.

### 8.3 Life of slip-ring

The slip-ring's surface using NG-brush is fine and its colour is a bit maroon-copper.

As NG-brush has proper hardness and bending strength and does not show any fire-spark during operation, the slip-ring's surface does not get molten, damaged and scratched. Therefore, it is considered that there's nearly no damage by NG-brush (see Annex A).

## 8.4 Environmental pollution

### 8.4.1 Dust diffusion by wear of brush

Table 5 shows dust diffusion evaluated by the wear of NG-brush and copper brush.

**Table 5 – Comparison of wear of NG-brush and copper brush**

Denomination	Total wear per 1 000 h g	
	NG-brush	Copper brush
Escalator motor (36 brushes per unit)	21,6	750
NOTE The wear is the same as the other wound rotor-type induction motor.		

As shown in Table 5, copper brush generates up to 34,7 times more dust than NG-brush does. This dust contaminates the environment of the area or causes a short-circuit by entering the gaps in the surrounding assemblies.

The wear of NG-brush is extremely low and this small amount of dust becomes a protection film for the surface of the slip-ring. Therefore there is nearly no dust that flies in the air.

#### **8.4.2 Pollution by noise**

In comparing NG-brush with copper brush during operating the wound rotor-type induction motor, there was far less noise in motors using the NG-brush.

As the slip-ring's brush made from NG-material has less fire-spark, noise and dust, it is considered that it satisfies the requirements of IEC 61000-4-2:2001, IEC 61000-6-2:1997 and ISO 14031:1999.

### **8.5 Economic profit**

#### **8.5.1 Brush price**

As there are no copper powders used in NG-brush, it is remarkably cheaper than copper brush.

#### **8.5.2 Brush life**

Because NG-brush is several times as long as copper brush's life, the operational expense is remarkably lower than copper brush.

#### **8.5.3 No accident due to dust diffusion and slip-ring's life**

Because the slip-ring is not damaged and insulation resistance of the winding does not fall, the maintenance cycle of the motor is long.