



UL 428B

STANDARD FOR SAFETY

Electrically Operated Valves for Diesel Fuel, Biodiesel Fuel, Diesel/Biodiesel Blends with Nominal Biodiesel Concentrations Up To 20 Percent (B20), Kerosene, and Fuel Oil

ULNORM.COM Click to view the full PDF of UL 428B 2021

[ULNORM.COM](https://www.ulnorm.com) : Click to view the full PDF of UL 428B 2021

UL Standard for Safety for Electrically Operated Valves for Diesel Fuel, Biodiesel Fuel, Diesel/Biodiesel Blends with Nominal Biodiesel Concentrations Up To 20 Percent (B20), Kerosene, and Fuel Oil, UL 428B

First Edition, Dated June 5, 2015

Summary of Topics

This revision of ANSI/UL 428B dated February 5, 2021 is issued to Equate Long Term Exposure Testing Duration – Valve and End Product; [26.3.3](#)

Text that has been changed in any manner or impacted by UL's electronic publishing system is marked with a vertical line in the margin.

The revised requirements are substantially in accordance with Proposal (s) on this subject dated November 6, 2020.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 428B 2021

JUNE 5, 2015
(Title Page Reprinted: February 5, 2021)



ANSI/UL 428B-2021

1

UL 428B

**Standard for Electrically Operated Valves for Diesel Fuel, Biodiesel Fuel,
Diesel/Biodiesel Blends with Nominal Biodiesel Concentrations Up To 20
Percent (B20), Kerosene, and Fuel Oil**

Prior to the first edition, the requirements for the products covered by this standard were included in the Outline of Investigation for Electrically Operated Valves for Diesel Fuel, Biodiesel Fuel, Diesel/Biodiesel Blends with Nominal Biodiesel Concentrations Up To 20 Percent (B20), Kerosene, and Fuel Oil, UL 428B.

First Edition

June 5, 2015

This ANSI/UL Standard for Safety consists of the First Edition including revisions through February 5, 2021.

The most recent designation of ANSI/UL 428B as an American National Standard (ANSI) occurred on January 22, 2021. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2021 UNDERWRITERS LABORATORIES INC.

No Text on This Page

[ULNORM.COM](https://ulnorm.com) : Click to view the full PDF of UL 428B 2021

CONTENTS

INTRODUCTION

1	Scope	7
2	General	7
	2.1 Components	7
	2.2 Units of measurement	8
	2.3 Undated references	8
	2.4 Automotive-fuel valve	8
3	Glossary	8

CONSTRUCTION

4	General	10
5	Assembly	10
	5.1 All valves	10
	5.2 Safety valves	10
	5.3 Class 2 (low-voltage) valves	11
6	Materials	11
	6.1 Metallic materials	11
	6.2 Nonmetallic materials	12
	6.3 Casting impregnation materials	14
	6.4 Internal parts – fluid compatibility	14
	6.5 Insulating Materials	14
7	Fluid Connections	16
8	Seals and Stuff Boxes	17
9	Springs	17
10	Diaphragms	17
11	Operating Mechanisms	18
12	Current-Carrying Parts	18
13	Enclosures	18
	13.1 General	18
	13.2 Metallic enclosures	19
	13.3 Polymeric enclosures	21
	13.4 Enclosure conduit connection	22
	13.5 Openings	23
	13.6 Accessibility of live parts	25
	13.7 Screens and expanded metal	27
	13.8 Rainproof, raintight, and watertight enclosures	27
	13.9 Corrosion protection	28
	13.10 Safety valves	29
14	Field Wiring Connections	30
	14.1 General	30
	14.2 Leads	30
	14.3 Field Wiring Terminals	31
	14.4 Wiring space	32
15	Internal Wiring	32
16	Grounding and Bonding	33
17	Protection of Users and Service Personnel	34
18	Transformers, Coils and Motors	34
19	Switches	35
20	Spacings	35
	20.1 General	35
	20.2 High-voltage circuits	35

20.3	Low-voltage circuits – and low-voltage safety-control circuits	39
20.4	Other than safety-control circuits	39
21	Alternate Spacing – Clearances and Creepage Distances	39
22	Separation of Circuits	40
22.1	General.....	40
22.2	Barriers.....	41

PERFORMANCE

23	General	41
24	Input Test	43
25	Temperature Test	43
26	Long Term Exposure Test	47
26.1	General.....	47
26.2	Samples	47
26.3	Method	48
26.4	Results	48
27	Operation Test	49
28	Torque Test	49
28.1	All valves	49
28.2	Safety valves.....	50
29	External Leakage Test	50
30	Seat Leakage Test	51
31	Endurance Test.....	51
32	Vibration Test – Safety Valves	51
33	Hydrostatic Strength Test	52
34	Dielectric Voltage-Withstand Test	52
35	Increased Potential Test	53
36	Burnout Test	53
37	Breakdown of Component Test	54
38	Rain Test	55
39	Hosedown Test	58
40	Metallic Coating Thickness Test	58
41	Clamped Insulating Joints in Lieu of Spacings	59
42	Printed Wiring Board Abnormal Operation Test	61
43	Sight Glass Impact Test	62
44	Sight Glass Temperature Shock Test	62

MANUFACTURING AND PRODUCTION

45	General	63
----	---------------	----

ELECTRICAL RATINGS

46	Details	63
----	---------------	----

MARKING

47	Details	63
48	Cautionary Markings	65
49	Visibility and Permanence of Markings	66
49.1	General.....	66
49.2	Unusual-condition exposure test.....	66

SUPPLEMENT SA – MARINE USE ELECTRICALLY OPERATED SHUT-OFF VALVES FOR DIESEL FUEL, BIODIESEL FUEL, DIESEL/BIODIESEL BLENDS WITH NOMINAL BODIESEL CONCENTRATIONS UP TO 20 PERCENT (B20), KEROSENE, AND FUEL OIL

SA1	Scope	67
SA2	Installation and Operating Instructions	67
SA3	General	67
SA4	Materials	68
SA5	Electrical Connections	68
SA6	General	68
SA7	Vibration Test	68
SA8	Shock Test	68
SA9	Ignition Protection Test	69
SA10	Fire Test	69
SA11	Operation and Temperature Tests	71
	SA11.1 Low temperature	71
	SA11.2 Abnormal operation	71
	SA11.3 Normal operation.....	71
SA12	Details	71

SUPPLEMENT SB – Test Fluids

SB.1	Representative Aggressive Combustible Test Fuel Mixtures	73
------	--	----

ULNORM.COM : Click to view the full PDF of UL 428B 2021

No Text on This Page

[ULNORM.COM](https://www.ulnorm.com) : Click to view the full PDF of UL 428B 2021

INTRODUCTION

1 Scope

1.1 These requirements cover electrically operated general purpose and safety valves rated 600 volts or less and intended for the control of the fluids specified in [1.2](#). Electrically operated valves, other than automotive fuel valves, covered by these requirements are intended to be used in other than hazardous locations as defined in accordance with the National Electrical Code, ANSI/NFPA 70.

1.2 Electrically operated valves for use in dispensing devices are intended for use with one or more of the following:

- a) Diesel fuel, which includes renewable diesel and diesel/biodiesel blends with nominal biodiesel concentrations up to 5 percent (B0 – B5) formulated in accordance with the Standard Specification for Diesel Fuel Oils, ANSI/ASTM D975.
- b) Diesel/biodiesel, renewable diesel/biodiesel blends, blends with nominal biodiesel concentrations from 5 percent up to 20 percent (B6 – B20) formulated in accordance with the Standard Specification for Diesel Fuel Oil, Biodiesel Blends (B6 – B20), ANSI/ASTM D7467.
- c) Biodiesel (B99.9/B100) formulated in accordance with the Standard Specification for Biodiesel Fuel Blend Stock (B100) for Middle Distillate Fuels, ANSI/ASTM D6751.
- d) Kerosene formulated in accordance with the Standard Specification for Kerosene, ANSI/ASTM D3699.
- e) Fuel oil (heating oil) formulated in accordance with the Standard Specification for Fuel Oils, ANSI/ASTM D396.

1.3 These requirements cover valves whose coils are powered by a Class 2 (low-voltage) source. Valves incorporating a high-voltage transformer with a low-voltage secondary as an integral part of the valve assembly, are also covered by these requirements.

1.4 These requirements do not cover valves for use with fluids other than as specified in [1.2](#).

1.5 These requirements do not cover valves employing electrical parts, including coils, switch contacts and resistance elements, located in the flammable gas containing compartment of a valve. Valves constructed as such shall comply with the requirements in the Standard for Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations, UL 913.

2 General

2.1 Components

2.1.1 Except as indicated in [2.1.2](#), a component of a valve covered by this standard shall comply with the requirements for that component.

2.1.2 A component is not required to comply with a specific requirement that:

- a) Involves a feature or characteristic not required in the application of the component in the product covered by this standard, or
- b) Is superseded by a requirement in this standard.

2.1.3 A component shall be used in accordance with its rating established for the intended conditions of use.

2.1.4 Specific components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions.

2.2 Units of measurement

2.2.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

2.2.2 Unless indicated otherwise all voltage and current values mentioned in this standard are root-mean-square (rms).

2.3 Undated references

2.3.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

2.4 Automotive-fuel valve

2.4.1 An automotive fuel valve shall comply with the requirements applicable to safety valves, UL 429.

3 Glossary

3.1 For the purpose of this standard the following definitions apply.

3.2 AUTOMOTIVE-FUEL VALVE – An electrically operated valve rated for use with a direct current (DC) circuit and intended for use as a fuel-line shutoff valve on mobile equipment.

3.3 DIESEL/BIODIESEL BLEND – Blended fuels composed of a diesel component and a biodiesel component. The numerical value corresponding to the biodiesel component determines the blend rating (such as B20 for 20% biodiesel, 80% diesel).

3.4 ELECTRICAL CIRCUITS –

a) Class 2 Circuit – A circuit involving a potential of not more than 42.4 volts peak supplied by:

1) An isolating source that complies with the requirements in the Standard for Class 2 Power Units, UL 1310, or the requirements in the Standard for Low Voltage Transformers – Part 1: General Requirements, UL 5085-1, and the Standard for Low Voltage Transformers – Part 3: Class 2 and Class 3 Transformers, UL 5085-3

2) A dry cell battery having output characteristics no greater than those of an inherently limited Class 2 transformer; or

3) A combination of a rechargeable battery and a fixed impedance or regulating network that complies with the applicable performance requirements for an inherently limited Class 2 transformer.

b) Low-Voltage Circuit – A circuit involving a potential of not more than 30 volts ac (42.4 volts peak or direct current) and supplied from transformer output windings which are electrically isolated (i.e. insulated from ground). A circuit derived from a source of supply classified as a high voltage circuit,

by connecting resistance in series with the supply circuit as a means of limiting the voltage and current, is not considered to be a low voltage circuit. Unless the isolating transformer is provided as part of the valve or marked per [47.7](#), the circuit shall be considered a high voltage circuit.

c) High-Voltage Circuit – A circuit involving a potential of not more than 600 volts and having circuit characteristics in excess of those of a low-voltage circuit.

d) Intrinsically Safe Circuit – A circuit in which any spark or thermal effect produced either normally or in specified fault conditions, is incapable of causing ignition of a mixture of flammable or combustible material in air in the mixtures most easily ignited concentration under the test conditions specified in the Standard for Intrinsically Safe Apparatus and Associated Apparatus, for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations, UL 913.

e) Safety-Control Circuit – A circuit involving one or more safety controls.

3.5 GENERAL PURPOSE VALVE – Either a normally open or normally closed valve intended to control the flow of a fluid.

3.6 MAXIMUM OPERATING PRESSURE DIFFERENTIAL – The maximum difference between the pressure at an inlet port and the pressure at an outlet port against which an electrically operated valve is intended to operate.

3.7 MAXIMUM RATED PRESSURE – The maximum pressure to which the valve assembly may be subjected as specified by the manufacturer.

3.8 MINIMUM OPERATING PRESSURE DIFFERENTIAL – The minimum difference between the pressure at an inlet port and the pressure at an outlet port required for operation of the valve.

3.9 RAINPROOF ENCLOSURE – An enclosure that prevents rain from interfering with the intended operation of apparatus within the enclosure.

3.10 RAIN TIGHT ENCLOSURE – An enclosure that, when exposed to a beating rain, does not permit water to enter the enclosure.

3.11 SAFETY VALVE – A normally closed valve intended to be actuated by a safety control or by an emergency device to prevent the delivery of a fluid that can result in risk of fire.

3.12 SEALS, DYNAMIC – A seal that is subject to mechanical movement or other applied forces that result in movement or flexing of the seal under normal use conditions.

3.13 SEALS, STATIC – A seal that is not subject to mechanical movement or other applied forces other than compression forces that are applied during installation and maintained during normal use conditions.

3.14 SWITCH – A contact device actuated by the valve mechanism and intended to control electrical loads that are internal or external to the valve.

a) Safety Switch – A switch that opens and closes a safety-control circuit, or one intended for use as an interlock in a safety-control circuit.

b) Nonsafety Switch – A switch not associated with a safety-control circuit.

3.15 WATERTIGHT ENCLOSURE – An enclosure that, when subjected to the application of a hose stream as described in the Hosedown Test, Section [39](#), does not permit water to enter the enclosure.

CONSTRUCTION

4 General

4.1 Valves shall be constructed so that they comply with the rules for installation and use of such equipment as given in the National Electrical Code, NFPA 70.

4.2 Fluid confining parts, except gaskets and seals, shall be constructed of metallic materials.

5 Assembly

5.1 All valves

5.1.1 A valve shall include all the components necessary for its intended function and installation. The components shall be constructed for assembly as a unit.

5.1.2 Two or more subassemblies intended to be assembled in the field as a unit shall be capable of being joined together without requiring any of the subassemblies to be cut, drilled, welded, or otherwise altered.

5.1.3 If two or more valves or actuating devices, or both, are intended to be used together as one unit, the entire assembly is to be considered and tested as one valve.

5.1.4 The construction of a valve shall be such that parts can be reassembled after being dismantled to the extent needed for servicing.

5.1.5 A screwed cap or cover that constitutes a fluid-confining part, and that is intended to be removed for servicing a valve, shall require the use of a tool for removal.

5.1.6 A seat disc shall be attached to its poppet or holder or be otherwise assembled to prevent it from becoming dislocated under service conditions. The disc may be secured by crimping, staking, or the equivalent, or by means of a chemical bond achieved by vulcanization in a controlled molding process. Cement or adhesive shall not be used as the sole means for securing a disc.

5.1.7 The valve assembly shall withstand the stresses and vibration of intended operation, as determined by compliance with the Endurance Test, Section [28](#).

5.2 Safety valves

5.2.1 A safety valve shall not depend on an outside source of energy, such as electricity, to function as a safety shutoff.

5.2.2 A safety valve shall close independently of the energy supplied by the medium flowing. However, the medium flowing may be used to exert supplementary closing forces on the valve seat.

5.2.3 A safety valve shall not be equipped with a bypass or with a means to prevent it from closing completely. This requirement does not apply to a feature provided to permit a takeoff to recirculate fluid or to supply a pilot or other individually controlled outlet.

5.2.4 An automatic shutoff mechanism shall be guarded to prevent unintended obstruction of moving parts.

5.2.5 A safety valve shall also function as a safety shutoff if intended to function as a safety shutoff, regardless of the position of any damper or external operating lever or any reset device. The manipulation of a manual-reset device shall not cause the valve to function as an automatic-reset valve.

5.2.6 A safety valve shall not be equipped with means for manually latching the valve in the open position if such latching may prevent the valve from functioning as a safety shutoff.

5.2.7 The appropriate positions or the direction of movement for a manual operating lever or reset handle included in a safety valve shall be clearly indicated.

5.2.8 If a mechanically actuated indicator is provided to indicate whether the main valve is open or shut, the indicator shall be visible from a distance of at least 5 feet (1.5 m).

5.3 Class 2 (low-voltage) valves

5.3.1 Valves whose coils are powered by a Class 2 (low-voltage) source shall comply with the construction and testing requirements defined in this standard, see Section [18](#).

6 Materials

6.1 Metallic materials

6.1.1 General

6.1.1.1 A metallic part, in contact with the fuels anticipated by these requirements, shall be resistant to the action of the fuel if degradation of the material will result in leakage of the fuel or if it will impair the function of the device. For all fuel ratings, see the Long Term Exposure Test Section [26](#).

6.1.1.2 The exposed surfaces of metallic parts shall be resistant to atmospheric corrosion if this corrosion will lead to leakage of the fluid or if it will impair the function of the device. The material shall comply with the requirements in Atmospheric corrosion, [6.1.2](#).

6.1.1.3 Metallic parts in contact with the fuels anticipated by these requirements shall not be constructed of lead, or materials that are substantially lead. In addition, no coatings or platings containing lead shall be used, such as terne-plated steel.

6.1.2 Atmospheric corrosion

6.1.2.1 Metallic materials used for fluid confining parts shall be resistant to atmospheric corrosion. Ferrous materials of the thickness specified in the following items are acceptable for the preceding when uncoated:

- a) A casting having a wall thickness of not less than 1/4 inch (6.4 mm) if shown by production test to be free of leakage, and
- b) Fabricated sheet steel parts having a minimum wall thickness of 0.093 inch (2.36 mm).

6.1.2.2 A protective coating shall provide resistance against atmospheric corrosion to a degree not less than that provided by the protective coatings specified in [6.1.2.3](#).

6.1.2.3 Cadmium plating shall not be less than 0.0003 inch (0.008 mm) thick, and zinc plating shall not be less than 0.0005 inch (0.013 mm) thick, except on parts where threads constitute the major portion of the area in which case the cadmium or zinc plating shall not be less than 0.00015 inch (0.0038 mm) thick.