



UL 6141

STANDARD FOR SAFETY

Wind Turbines Permitting Entry of
Personnel

[ULNORM.COM](https://www.ulnorm.com) : Click to view the full PDF of UL 6141 2022

[ULNORM.COM](https://ulnorm.com) : Click to view the full PDF of UL 6141 2022

UL Standard for Safety for Wind Turbines Permitting Entry of Personnel, UL 6141

First Edition, Dated May 20, 2016

Summary of Topics

This revision of ANSI/UL 6141 dated October 26, 2022 eliminates offshore exclusion from Scope;
1.3

Text that has been changed in any manner or impacted by UL's electronic publishing system is marked with a vertical line in the margin.

The revised requirements are substantially in accordance with Proposal(s) on this subject dated May 13, 2022.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page

[ULNORM.COM](https://ulnorm.com) : Click to view the full PDF of UL 6141 2022

MAY 20, 2016
(Title Page Reprinted: October 26, 2022)



ANSI/UL 6141-2022

1

UL 6141

Standard for Wind Turbines Permitting Entry of Personnel

First Edition

May 20, 2016

This ANSI/UL Standard for Safety consists of the First Edition including revisions through October 26, 2022.

The most recent designation of ANSI/UL 6141 as an American National Standard (ANSI) occurred on October 26, 2022. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2022 UNDERWRITERS LABORATORIES INC.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 6141 2022

CONTENTS

INTRODUCTION

1	Scope	5
2	General	6
	2.1 Components	6
	2.2 Units of Measurement	6
	2.3 Undated References	7
3	Glossary	7

WIND TURBINE EQUIPMENT AND SUBASSEMBLIES

4	Special Components and Subassemblies of Wind Turbines	9
	4.1 General	9
	4.2 Wiring	11
	4.3 Splices and connections in power cables	14
	4.4 Cable twist loop	15
	4.5 Bus bars	16
	4.6 Switchgear	17
	4.7 Panelboards	18
	4.8 Transformers	18
	4.9 Hub	20
	4.10 Converter/inverter	20
	4.11 Lightning protection systems	21
	4.12 Slip rings	21
	4.13 Gearboxes	22
	4.14 Hoists and winches	22
	4.15 Fire protection	22
	4.16 Emergency stop functionality for personnel protection	23
	4.17 Cable trays and wireways	24
	4.18 Hydraulic electromechanical components	24
	4.19 Alternators, generators and motors	24
	4.20 Motor drives	26
	4.21 Energy storage units	26
	4.22 Disconnect devices	28
	4.23 Battery charge controllers	29
	4.24 Medium voltage disconnection means	29
	4.25 Heating and cooling equipment	29
	4.26 Wind turbine tower elevators	29
5	Spacings	30
6	Components and Circuits Rated or Operating between 601V and 1000V	31
7	Grounding	32
8	Safety Related Controls System (SRCS)	32
	8.1 General	32
	8.2 Protection functions	33
	8.3 Abnormal conditions for safety related controls system	33
9	Manual Shutdown	34
10	Self-Excitation	34
11	Ratings	34

SERVICE PERSONNEL SAFETY

12	Working Space	35
----	---------------------	----

MARKINGS

13 System and Subassembly Components36
14 Cautionary Markings.....41

INSTRUCTIONS

15 General Installation – System and Subassembly.....43

APPENDIX A

UL Standards for Components44

APPENDIX B – IEC Standards for Components

APPENDIX C – IEEE Standards for Components

ULNORM.COM : Click to view the full PDF of UL 6141 2022

INTRODUCTION

1 Scope

1.1 These requirements cover large wind turbine systems (WT) that are equipped with electrical subassemblies and permit the entry of personnel. With respect to this standard, WT permitting entry of personnel are considered to be wind turbines where a user or service person may, or is intended to, enter the turbine to operate it or perform maintenance. These WT are intended for use in utility-interactive, grid-tied applications that operate in parallel with an electric power system (EPS) to supply power to common or stand-alone loads. This standard includes requirements for WT intended for EPS grid connections at transmission, sub-transmission, and distribution levels depending on the specifications of the specific WT.

1.2 The WT power, control and protection systems are evaluated only to the extent that they function within the manufacturer's specified limits and response times. These control and protection functions are evaluated with respect to risk of electric shock and fire. It is intended that the electrical subassemblies that address power transfer and control and protection functions evaluated per this document are to be coordinated with the mechanical and structural evaluation of the WT in accordance with the IEC 61400 series of documents.

1.3 These requirements do not cover:

- a) Deleted
- b) Mechanical or structural integrity of the WT or subassemblies,
- c) Verification that the manufacturer-defined controls and protection limits maintain the WT within its safe mechanical and structural limits,
- d) Compliance with specific grid interconnection standards or requirements.

1.4 The wind turbine products covered by these requirements are intended to be installed in multiple installation locations and jurisdictions which may include installation codes including, but not limited to, the National Electrical Code, ANSI/NFPA 70, the National Electrical Safety Code (NESC), and NFPA 79, Electrical Standard for Industrial Machinery.

1.5 The wind turbine products covered by this standard are considered to be machines that include inherent internal hazards that make them unsuitable for access by the general public.

1.6 The users, operators and service persons that enter this equipment are expected to have the necessary knowledge of its operation and reasonably foreseeable hazards. These individuals are expected to be equipped with the necessary equipment for the application and hazard.

1.7 The evaluation of products to this standard includes the evaluation of all features and functions incorporated in or available for the WT that can affect compliance of the WT with this standard. This includes references in the documentation for the WT.

1.8 Small WT and electrical subassemblies are defined as wind turbines where a user or service person is not intended or required to enter the WT to operate or perform maintenance on the WT. Small wind systems are covered in the Standard for Small Wind Turbine Systems, UL 6142.

2 General

2.1 Components

2.1.1 Except as indicated in [2.1.2](#), a component of a product covered by this standard shall comply with the requirements for that component. See Appendices [A](#) – [C](#) for a list of standards covering components used in the products covered by this standard.

2.1.2 A component is not required to comply with a specific requirement that:

- a) Involves a feature or characteristic not required in the application of the component in the product or system covered by this standard,
- b) Is superseded by a requirement in this standard, or
- c) Is not relied upon for compliance with the National Electric Code, ANSI/NFPA 70, and other U.S. installation codes, provided the component addresses the performance and safety critical aspects necessary for the end application as determined by the evaluation in this standard.

Note: the following provides guidance for item (c) –

- 1) Integral WT components relied upon to interconnect with and/or protect system components, system wiring, loads, etc. shall be of the type(s) defined in the applicable portion of the National Electric Code and shall comply with the applicable portions of the UL standards or standards referenced in the National Electric Code and in Appendix [A](#) for that component type or function. They shall be suitable for the application within the end product application, including the end product ratings and including foreseeable abnormal conditions. Examples include, but are not limited to, branch overcurrent protection, switches, disconnects, wire, cable, connectors, contactors, etc.
- 2) External WT system components (not integral to the WT) shall comply with applicable UL standard for that component.

2.1.3 A component shall be used in accordance with its rating established for the intended conditions of use.

2.1.4 Specific components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions.

2.1.5 Components and subassemblies of the overall WT shall be evaluated and found suitable for their operation over the rated normal operating range of electrical and environmental conditions within the WT per the WT manufacturer's specifications.

2.1.6 These components and subassemblies shall also perform per the manufacturer's specifications during defined abnormal conditions, such as WT shutdown and abnormal electric utility grid conditions.

2.1.7 For additional requirements, reference Section [4](#), Special Components and Subassemblies of Wind Turbines.

2.2 Units of Measurement

2.2.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

2.2.2 All references to AC voltages within this standard shall be considered to be RMS unless otherwise specified.